

Report supervisor-room number mistakes to [Linda Swihart](#)

As of 03/22/2005 12:54 PM only the white ones remain

Super	room	item	itemtext	recomm abatement time	abated	reply expected from:
??	5th Floor	labels	Container of chemical is unlabeled. Bucket of unknown sludge sitting on large duct WSW across walking path from 516 space.	immed	6-14-04	Swihart
Biochem Div	345E	width	Restore minimum aisle width of 22".	10 days	7-30-04	biochem div head
Biochem Div	345E	egress	Means of egress are obstructed or impeded by item(s) in or across walkway or corridor. (Door to 345F is blocked.)	immed	7-19-04	biochem div head
Biochem Div	352 Corridor	corridor	Corridor obstructed. Remove equipment, furniture or other items stored in the corridor.	10 days	7-1-04	biochem div head
Biochem Div Chmielewski	354	postdoor	Emergency telephone numbers (24 hours) must be posted on outside of lab door(s). See http://www.purdue.edu/rem/home/forms/DOORPOST.DOC	10 days	7-1-04	biochem div head
Biochem Div Chmielewski	354	hazass	Failure to post written Hazard Assessment Certification. See http://www.purdue.edu/rem/home/forms/HazAsTmp.doc and follow instructions/directions.	5 days	7-1-04	biochem div head
Biochem Div Chmielewski	354	fraycord	Power cord damaged or broken. Electrical tape is unacceptable. (Fisher Oven)	10 days	7-1-04 note: no oven found	biochem div head
Cooks	062	machineguard	Machine guard is missing. The 13" drill press is without a chuck guard.	immed	5-20-04	Chen
Cooks	062	electricsspace	Minimum clear space of 36" not maintained in front of switchboard. In SSE corner of room, 4 switch boxes are not reachable.	10 days	5-13-04	Chen
Creative Arts	182, in corridor	firedoor2	Fire doors must not be left propped open unless on magnetic hold opens that close when the fire alarm sounds.	immed	6-14-04	Swihart
Dirksen	015	sprinklers	Interference to sprinkler discharge because of building contents. Minimum vertical clearance between sprinklers and material below shall be 18". Stored lamps/light panels too close to sprinklers.	immed	6-4-04	Darrel
Dirksen	016D	corddamage	Flexible cords and/or cables not protected from accidental damage. Extension cord extends through doorway.	immed	6-4-04	Darrel
Dirksen	027, in corridor	firedoor2	Corridor fire doors must not be left propped open, without magnetic hold open devices that close if fire alarm sounds.	immed	6-4-04	Darrel
Dirksen	040	machineguard	Machine guard is missing. Delta table saw is without a blade guard.	immed	5-26-04	Darrel
Dirksen	040B	fraycord	Power cord damaged or broken. Electrical tape is unacceptable. The paint shaker's in-line on/off switch is broken, exposing wires.	10 days	6-7-04	Darrel
Dirksen	513	wastedisp	Apparently abandoned chemical waste -- used silica.	10 days	4-15-04	Darrel
Dirksen	581	sprinklers	Interference to sprinkler discharge. Minimum vertical clearance between sprinklers and material below is 18". Sprinklers obstructed in several locations, fixed one, could not reach others.	immed	4-16-04	Darrel
Dirksen	B180	aisle	Restore aisleway near elevator.	10 days	6-4-04	Darrel
Dirksen?	162B	aisle	Restore aisleway. There is storage in the aisle in this mechanical room.	10 days	5-18-04	Darrel
Dirksen?	506	fuelload	Excessive or unsafe fire fuel load/storage. Excessive plastics and paper, wood, some leaning on hot radiators.	immed	6-18-04	Darrel
Fuchs	450A	genduty	Workplace not reasonably free of recognized hazards. Need SOP for Ozonolysis set-up. Not covered in the Chemical Hygiene Plan manual.	10 days	6-28-04 Ozonolysis Procedures Manual is in 4103 from Doug Lantrip	Lee
Grutzner	441	fraycord	Power cords damaged or broken. There appears to be a nontrivial collection of small appliances set aside in need of cord repairs, but it also appears that they are just collecting dust. Send for repairs or dispose ASAP.	10 days	Aug 1 .04	Grutzner
Grutzner	463	fraycord	Power cords damaged or broken. Corning hotplate stirrer in hood C, also Variac in hood B.	10 days	Aug 1 .04	Grutzner
Kais/Szleifer	265	gfci	Workplace not reasonably free of recognized hazards: duplex outlet in kitchenette without GFCI protection. Submit OSHA 113 to REM. REM will issue 18-A. P59 is not required. (3 NEEDED)	60 days	8-2-04	Swihart
Kitchenette	202	gfci	Workplace not reasonably free of recognized hazards: duplex outlet in kitchenette without GFCI protection. Submit OSHA 113 to REM. REM will issue 18-A. P59 is not required.	60 days	8-2-04	Swihart
Lipschutz	145 to 150, in corridor	corridor	Corridor obstructed. Remove equipment, furniture or other items stored in the corridor: credenza, desk and two book cases.	10 days	6-7-04	Lipschutz or Swihart
Lipschutz	155 to 159, in corridor	corridor	Corridor obstructed. Remove equipment, furniture or other items stored in the corridor: 5 bookcases.	10 days	7-5-04	Lipschutz or Swihart

Low	327D	hazass	Failure to post written Hazard Assessment Certification. See http://www.purdue.edu/rem/home/forms/HazAsTmp.doc and follow instructions/directions.	5 days	6-19-04	Simon
Low	327E	hazass	Failure to post written Hazard Assessment Certification. See http://www.purdue.edu/rem/home/forms/HazAsTmp.doc and follow instructions/directions.	5 days	6-19-04	Simon
Low	333B	opencont	Open chemical containers not in use.	immed	at inspection	Simon
Low	333C	washaccess	Eyewash and/or shower is obstructed.	immed	5-20-04	Simon
Low	333C	combuststorage	Combustible materials not stored safely. Flammables stored next to ignition source inside fume hood.	immed	at inspection	Simon
Low	333C	labels	Container of chemical is unlabeled.	immed	at inspection	Simon
Low	357	desig	Failure to designate areas for select carcinogens, reproductive hazards, and/or extremely toxic chemicals. Use supplied "CAUTION" stickers as needed in these areas. See http://www.purdue.edu/rem/home/booklets/crdalist.doc	10 days	6-4-04	Simon
Low	357	opencont	Open chemical containers not in use.	immed	at inspection	Simon
Low	357	combuststorage	Combustible materials not stored safely. Methyl alcohol stored next to hot plate/stirrer inside fume hood.	immed	at inspection	Simon
Low	357	labels	Container of chemical is unlabeled.	immed	at inspection	Simon
Low	357	genduty	Workplace not reasonably free of recognized hazards. Do not hang lab coats on cylinder valves.	10 days	at inspection	Simon
Low	357	refrig	Chemical storage refrigerator(s) and/or freezer(s) neither lab safe nor posted as "NO FLAMMABLES." See http://www.purdue.edu/rem/home/forms/flamesaf.doc	10 days	6-4-04	Simon
Morrison	430C	firedoor2	Fire doors must not be left propped open when room is unattended. Doors are posted KEEP CLOSED AT ALL TIMES.	immed	6-10-04	Ho
Morrison	430C	segregate	Stored chemicals are not segregated by hazards. Concentrated strong oxidizing acids (nitric, sulfuric... under hood B) are not compatible with much else, need separate storage.)	immed	6-11-04	Ho
Morrison/Wei	440B	firedoor2	Fire doors must not be left propped open when room is unattended. Doors are posted KEEP CLOSED AT ALL TIMES.	immed	6-10-04	Ho
Morrison/Wei	440B	cylinder	Unsecured or inadequately secured compressed gas cylinder(s). Uncapped should be secured individually.	immed	6-10-04	Ho
Morrison/Wei	440B	flamcab	Excess flammables stored outside of approved cabinet and/or safety cans.	60 days	6-11-04	Ho
Morrison/Wei	440B	labels	Containers of chemicals unlabeled. Hood D. Untended research chemical containers must have ID.	immed	6-10-04	Ho
Morrison/Wei	440B	openwaste	Open chemical waste containers not in use. Hood D, RBF with funnel identified as waste by other lab staff.	immed	6-10-04	Ho
Pirola	427	misc	Need visible emergency evacuation alarm and/or more audible alarm installed in immediate area (Glassblower Laboratory). Department submit P-59 for estimate to repair. Department expense to repair.	60 days	*****	Robinson or Dirksen
Rafferty	4144A	hazasstailor	Hazard assessment certification is posted but is not tailored to this work area. Re-create without unnecessary items, new date, signature, post so both pages visible if two pages result, make rules clear, appropriate and enforced.	10 days	6-18-04	Reyes
Rafferty	4152	alcohol	Alcoholic beverages are stored in this area, or evidence of consumption. Remove/dispose alcoholic beverage bottles.	immed	4-14-04	Reyes
Ramachandran	222	postdoor	Emergency telephone numbers (24 hours) must be posted on outside of lab door(s). See http://www.purdue.edu/rem/home/forms/DOORPOST.DOC	10 days	4-18-04	Garner
Ramachandran	5125	flamcab	Excess flammables stored outside of approved cabinet and/or safety cans, or cabinet malfunctioning, improperly configured, or not kept closed. Flammable waste container exceeds 10 gallons.	60 days	4-18-04	Garner
Ramachandran	5125	labels	Container of chemical is unlabeled. Many wash bottles are without contents and hazards labels.	immed	4-12-04	Garner
Ramachandran	5125	hazasstailor	Hazard assessment certification is posted but is not appropriate to this work area. Remove WELDING and any other sections not necessary. Ensure that rules are clear, appropriate and enforced.	10 days	4-16-04	Garner
Ramachandran	5125	acronyms	Containers of chemicals are inadequately labeled. If acronyms, formulae, or abbreviations are used, post a legend/key near inside of entrance to room. See http://www.purdue.edu/rem/home/booklets/Acronyms.xls	immed	4-12-04	Garner
Ramachandran	5125	fraycord	Power cord damaged or broken. Electrical tape is unacceptable. The multiple outlet bar located near the Mettler P1200N balance has a power cord that is broken throughout its length.	10 days	4-18-04	Garner
Ramachandran	5125	egress	Means of egress are obstructed or impeded by item(s) in or across walkway or corridor. A box blocks the north emergency exit door.	immed	4-5-04	Garner
Ramachandran	5135	hazasstailor	Hazard assessment certification is posted but is not appropriate to this work area. Remove WELDING and any other sections not necessary. Ensure that rules are clear, appropriate and enforced.	10 days	4-16-04	Garner
Ramachandran	5135	acronyms	Containers of chemicals are inadequately labeled. If acronyms, formulae, or abbreviations are used, post a legend/key near inside of entrance to room. See http://www.purdue.edu/rem/home/booklets/Acronyms.xls	immed	4-5-04	Garner
Ramachandran	5135	eyelevel	Display written SOP for accessing extremely high containers of liquids, or move containers of liquids stored above eye level to eye level or below.	30 days	4-18-04	Garner
Ramachandran	5135	fraycord	Power cord damaged or broken. Electrical tape is unacceptable. Heat mantle's power cord is broken and taped, hood D.	10 days	4-5-04	Garner
Regnier	3174B	egress	Means of egress are obstructed or impeded by item(s) in or across walkway or corridor. (Access to 3174C)	5-25-04		Seeley
Regnier	3184	labels	Container of chemical is unlabeled.	5-10-04		Seeley

Santini	073	machineguard	Machine guard is missing. Bridgeport mill is without a chuck guard	5-16-04	PPE sign will be installed by July 1, 2004	Everly
Santini	073	machineguard	Machine guard is missing. Lathe is without a chuck guard.	5-16-04	PPE sign will be installed by July 1, 2004	Everly
Santini	073	machineguard	Machine guard is missing. Delta drill press is without a chuck guard.	5-16-04	PPE sign will be installed by July 1, 2004	Everly
Santini	075	machineguard	Machine guard is missing. Monarch lathe is without a chuck guard.	5-16-04	PPE sign will be installed by July 1, 2004	Everly
Santini	075	machineguard	Machine guard is missing. Large Monarch lathe is without a chuck guard.	5-16-04	PPE sign will be installed by July 1, 2004	Everly
Santini	075	machineguard	Machine guard is missing. Johanson drill press is without a chuck guard.	5-16-04	PPE sign will be installed by July 1, 2004	Everly
Santini	075	misc	Flash back and back flow preventers needed on oxygen and acetylene tanks after the regulators.	5-16-04	flash-back hardware will be ordered ASAP	Everly
Santini	075	grinder	Craftsman pedestal grinder is without tongue guards adjusted to no more than 1/4" clearance above the abrasive wheels.	5-16-04	GUARDS WILL BE ADDED AND ADJUSTED AS NEEDED	Everly
Santini	081	genduty	Workplace not reasonably free of recognized hazards. An 18"x12" piece of asbestos needs to be removed from the workplace. Contact Kevin Thedans phone 61937 to arrange for its removal.	5-16-04	Thedans will be asked to remove asbestos ASAP	Everly
Santini	4151A	housekeep	Restore housekeeping. (Sweep up small amount of metal turnings on floor in corner.)	5-16-04	Complete cleanup by June 11, 2004	Everly
secretary	4150	fraycord	Power cord damaged or broken at plug. East wall, cord goes up into ceiling to unknown location.	10 days	6-5-04	Dirksen
Skrynnikov	333D	opencont	Open chemical containers not in use.	immed	5-20-04	Simon
Skrynnikov	333E	openwaste	Open chemical waste containers not in use.	immed	5-20-04	Simon
Skrynnikov	345A	labels	Container of chemical is unlabeled.	immed	5-20-04	Simon
Vacant	101	electricspace	Minimum clear space of 36 " not maintained in front of switchboard. Safety switch on south wall is obstructed.	10 days	6-14-04	Swihart
Vacant	101	electricspace	Minimum clear space of 36 " not maintained in front of switchboard. Safety switch in SSE corner is obstructed	10 days	6-14-04	Swihart
Vacant	101B	combuststorage	Combustible materials not stored safely. More than 25 large empty cardboard boxes need to be removed or collapsed for storage.	immed	6-14-04	Swihart
Wei	413	labels	Containers of chemical unlabeled -- unattended flasks in hoods C, G. Check all areas.	immed	5-14-04	Jean
Wei	413	fraycord	Power cord damaged or broken. Pump in hood C	10 days	5-14-04	Jean
Wei	413	chemhousekeep	Chemical spills anywhere must be cleaned up immediately. See hoods D, G.	10 days	5-14-04	Jean
Wei	413	hoodcrowd	Chemical hood unsafe due to storage of flammable liquid containers in same area where chemical reactions performed and sources of heat and/or sparks exist..	10 days	5-14-04	Jean
Wei	440	flamcab	Excess flammables stored outside of approved cabinet and/or safety cans.	60 days	5-14-04	Jean
Wood	144	electricspace	Minimum clear space of 36 " not maintained in front of switchboard. Two electrical safety switches in the NE corner of the room are obstructed.	10 days	P-59 submitted 5/4/04 - Complete as of 6-17-04	Wood
Wood/Lipschutz	145, in corridor	electricspace	Minimum clear space of 36 " not maintained in front of switchboard.	10 days	5-5-04	Wood

***** The alarms in the glass lab are still in progress. P-59 complete, cost for new full circuit will be \$2000, and Central Shops has not scheduled it yet due to staff changes but as of 10/25/04 it should be at or near the top of their list.